

Certificate of Compliance

Certificate Number **112707-E175531**
Report Reference **E175531, November 12, 2007**
Issue Date **2007 November 27**

Page 1 of 2



Issued to: **Hirschmann Automation & Control GmbH**
Stuttgarter Str 45-51
Neckartenzlingen, 72654
Germany

This is to certify that representative samples of

Listed Programmable Controller

Type 1, Name Octopus, models no. OCTOPUS followed by 8 or 16 or 24, followed by M, may be followed by a slash and additional suffixes. They are all intended for installation entirely within a Class 2 circuit.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:


CNL - Indicates investigation to Canadian National Standard(s) C22.2 No. 142-M1987. USL - Indicates investigation to the United States Standard UL 508, 17th Edition (Industrial Control Equipment).

Additional Information:

ELECTRICAL RATINGS: Power supply: 60V Class 2, 2A max. Signal contact: 24V, 1A max. Maximum ambient: 75°C max. Pollution degree:3 Environmental Type:1

MODEL DIFFERENCEIES: The number of ports, 8, 16 or 26 with or without fibreoptic ports.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: Lijia Ma

Lijia Ma, Project Engineer

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions in The United States of America you may call 1-877-UL-HELPS.

Reviewed by: Pete Joyes

Pete Joyes, Staff Engineer

UL International Germany GmbH