

CERTIFICATE OF COMPLIANCE

Certificate Number E510457
Report Reference E510457-20191007
Issue Date 2023-MARCH-18

Issued to: Hirschmann Automation and Control GmbH
Stuttgarter Str. 45-51
72654 Neckartenzlingen, GERMANY

**This certificate confirms that
representative samples of**

TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS
LOCATIONS

See next page for models.

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

See next page for Standards for Safety.

See UL Product iQ® at <https://iq.ulprospector.com> for
additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E510457
Report Reference E510457-20191007
Issue Date 2023-MARCH-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Groups A, B, C and D, Open type industrial cellular gateways, models:
OWL-IPG-AMERICAS

Class I, Division 2, Groups A, B, C and D, Edge Gateway, models:
EAGLE40-4F, OpEdge-4D, OpEdge-4D-LTE

Standard(s) for Safety:

UL 121201 and CAN/CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations


UL 61010-1 and CAN/CSA No. 61010-1-12, Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use Part 1: General Requirements

UL 61010-2-201 and CSA C22.2 NO. 61010-2-201:18, Safety Requirements For Electrical Equipment For Measurement, Control And Laboratory Use - Part 2-201: Particular Requirements For Control Equipment

CSA C22.2 No. 213-M1987 (R2013)- Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 508-Standard for Industrial Control Equipment

CSA C22.2 No. 142-M1987-Process Control Equipment



Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

