

Certificate of Compliance

Certificate Number:

E510457

Report Reference:

E510457-20171007

Issue Date:

2025-AUGUST-06

Issued to:

**Hirschmann Automation and Control GmbH
Stuttgarter Str 45-51 Neckartenzlingen 72654
Germany**

This certificate confirms that representative samples of:

TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS (WYMW, WYMW7)

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

See Addendum Page for Standards

Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): E510457
Report reference: E510457-20171007
Issue Date: 2025-AUGUST-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Products Covered	Product Designation	Nomenclature
Class I, Division 2, Group A, B, C and D, Open type industrial cellular gateways	OWL-IPG-AMERICAS	
Class I, Division 2, Group A, B, C and D, Edge Gateway	EAGLE40-4F	
Class I, Division 2, Group A, B, C and D, Advanced Edge Gateway	IAF-240	
Class I, Division 2, Group A, B, C and D, Edge Gateway	OpEdge-4D	
Class I, Division 2, Group A, B, C and D, Edge Gateway	OpEdge-4D-LTE	

Standards for Safety:

UL 121201 and CAN/CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

UL 61010-1 and CAN/CSA No. 61010-1-12, Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use Part 1: General Requirements

UL 61010-2-201 and CSA C22.2 NO. 61010-2-201:18, Safety Requirements For Electrical Equipment For Measurement, Control And Laboratory Use - Part 2-201: Particular Requirements For Control Equipment

CSA C22.2 No. 213-M1987 (R2013)- Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 508-Standard for Industrial Control Equipment

CSA C22.2 No. 142-M1987-Process Control Equipment



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.