

Manufacturer`s Declaration of Conformity

Hirschmann Automation and Control GmbH

**Stuttgarter Straße 45-51
D-72654 Neckartenzlingen, Germany**

declares in sole responsibility, that the product(s)

WLAN Access Point / Client

(Product description)

BAT-R, BAT-F

with the following possible product codes:

- BAT-R [nn] [W] [W|9] [9] [A|C] [K|C|W|P] [K|C|W|9] [I] [n] [n] [O7] [T1|99]

[S*|T|E] [n] [n] [n] [H|Z|9] [H] [nn.nn.nnnn]

- BAT-F [nn] [W] [W|9] [9] [A|C] [K|C|W|P] [K|C|W|9] [I] [n] [n] [O5] [T6|99]

[S*|T|E] [n] [n] [n] [H|Z|9] [H] [nn.nn.nnnn]

assembled with the transceivers M-SFP-x*, M-SFP-x EEC.

(n = any letter, x = any suffix)

* = Standard temperature range – heated and/or cooled enclosed locations

(Type, reference number)

has been designed and manufactured in accordance with the following standards

IEC/EN 61850-3:2014 – Communication networks and systems in substations

Test description	IEC 61850-3 Section	Test Reference	Requirement
Dry heat test operational	6.9.3.1	IEC 60068-2-2	+70 °C * +60 °C
Cold test operational	6.9.3.2	IEC 60068-2-1	-40 °C * 0 °C
Dry heat test storage	6.9.3.3	IEC 60068-2-1	+85 °C
Cold test storage	6.9.3.4	IEC 60068-2-2	-40 °C
Change of temperature test, operational	6.9.3.5	IEC 60068-2-14	-40 °C / 70 °C * 0 °C / 60 °C
Damp heat steady state	6.9.3.6	IEC 60068-2-78	Test Cab, 40 °C, 93% (10 days)
Damp heat cyclic test	6.9.3.7	IEC 60068-2-30	Test Db, 95 % (6 x 24h cycles)


Test description	IEC 61850-3 Section	Test Reference	Requirement
Vibration response and endurance (sinusoidal)	6.10.1	IEC 60255-21-1	Class 1 response: 10-59 Hz: 0,035 mm, 59-150 Hz: 0,5 g endurance: 59-150 Hz: 1,0 g
Shock response and shock withstand (half sine)	6.10.2	IEC 60255-21-2	Class 1 response: 5 g, 11 ms endurance: 15 g, 11 ms
Bumps	6.10.2	IEC 60255-21-2	Class 0
Seismic	6.10.3	IEC 60255-21-2	Class 1 1-8,5 Hz: 3,5 mm (x) / 1,5 mm (y) 8,5-35 Hz: 1 g (x) / 0,5 g (y)
IP protection class	6.11	IEC 60529	IP 20
Rated voltage, operating range	5.2	IEC 60870-2-1	<i>AC power ports:</i> Class AC3 (+10 % to -20 %) Urated: 110-230 V (KC) <i>DC power ports:</i> Class DC3 (+10 % to -20 %) Urated: 24 V (WW) 24-48 V (CC), 110-250 V (KC)
Product safety requirements	6.6.1	Clearances and creepage	Tests according to
	6.6.2	IP rating	EN 60950-1 passed.
	6.6.3	Impulse voltage	±5 kV
	6.6.4	Dielectric voltage test	0,7 kV DC (CC/WW) 2,8 kV DC (KC)
	6.6.5	Protective bonding resistance	0,1 Ω
	6.6.6	Flammability	EN 60950-1 passed.
	6.6.7	Single-fault condition	EN 60950-1 passed.
Electrostatic discharge	6.7.3	table 9.3 (Basic: IEC 61000-4-2)	Level 3, 6 kV contact / 8 kV air
Radiated electromagnetic field	6.7.3	table 9.2 (Basic: IEC 61000-4-3)	Level 3, 10 V/m 80 – 3000 MHz
Fast transient / burst	6.7.3	table 10.4, 11.5, 12.7 (Basic: IEC 61000-4-4)	<i>Signal ports, power ports:</i> CM Level 4, ±4 kV
Surges 1,2/50µs	6.7.3	table 10.2, 11.3, 12.5 (Basic: IEC 61000-4-5)	<i>Signal ports :</i> CM Level 4, ±4 kV <i>AC-power ports:</i> CM Level 4, ±4 kV DM Level 3, ±2 kV <i>DC-power ports:</i> CM Level 3, ±2 kV DM Level 2, ±1 kV

Test description	IEC 61850-3 Section	Test Reference	Requirement
Conducted disturbances by RF fields	6.7.3	table 10.5, 11.6, 12.8, 13.2 (Basic: IEC 61000-4-6)	Level 3, 10 V 150 kHz – 80 MHz
Power Magnetic field	6.7.3	table 9.1 (Basic: IEC 61000-4-8)	Level 5, 100A/m cont., 1000A 1s
Damped oscillatory wave 1MHz	6.7.3	table 10.3, 11.4, 12.6 (Basic: IEC 61000-4-12)	Signal ports, power ports: CM Level 3, 2,5 kV DM Level 3, 1,0 kV
Main frequency voltage	6.7.3	table 10.1, 12.4 (Basic: IEC 61000-4-16)	Signal ports, DC power ports: Level 4, 30 V cont., 300 V 1s
Ripple on DC power supply	6.7.3	table 12.3 (Basic: IEC 61000-4-17)	10 %
Voltage interruptions ¹⁾	6.7.3	table 11.1, 11.2	ΔU 30 %, 1 period ΔU 60 %, 50 periods ΔU 100 %, 5 periods ΔU 100 %, 50 periods
		Table 12.1, 12.2	ΔU 30 %, 0,1 s ΔU 60 %, 0,1 s ΔU 100 %, 50 ms
Radiated Emission	6.7.4	table 16.1, 17.1 CISPR22 / EN55022 Class A	30...230 MHz: 40 dB μ V/m (10m) 230...1000 MHz: 47 dB μ V/m (10m) 1...3 GHz: 56 dB(μ V/m) av. 76 dB(μ V/m) pk. (3m) 3...6 GHz: 60 dB(μ V/m) av. 80 dB(μ V/m) pk. (3m)
Conducted Emission	6.7.4	table 14.1, 15.1 CISPR22 / EN55022 Class A	Power ports: 150...500 kHz: 79 dB μ V qp. 66 dB μ V av. 500 kHz...30 MHz: 73 dB μ V qp. 60 dB μ V av. Telecommunication ports: 150...500 kHz: 97 to 87 dB μ V qp. 84 to 74 dB μ V av. 500 kHz...30 MHz: 87 dB μ V qp. 74 dB μ V av.

¹⁾ For a continuous operation according 7.5.2 C a redundant power source or UPS is recommended

IEEE 1613:2009 – Devices in Electrical Power Substations

Test description	IEEE 1613 Section	Test Reference	Requirement
Operational temperature range	3.1.1	-	-40 °C to +70 °C * 0 °C to +60 °C
Nonoperational temperature range	3.1.2	-	-40 °C to +85 °C
Relative humidity communication equipment	3.1.3	-	95 %, 96 hours
DC rated control power inputs	4.1	-	24 V rated, 32 V max. (WW) 48 V rated, 60 V max. (CC) 250 V rated, 280 V max. (KC)
AC component in DC control voltage supply	4.2	-	5% peak
AC rated control power inputs	4.3	-	120V-240 V, 50-60 Hz (KC)
Dielectric test	5.2	-	U _{rated} ≤ 48 V: 800 V DC (Transient protection allows a max DC-Offset ±60 V-U _{rated}) U _{rated} > 48 V ≤ 250 V: 2000 V _{rms} (Transient protection allows a max DC-Offset ±500 V-U _{rated})
Impulse voltage test	5.3	-	±5 kV
Oscillatory wave test 1MHz	6	-	2,5 kV CM 2,5 kV DM
Fast transient / burst	6	-	±4 kV CM
Radiated electromagnetic field	7	-	20 V/m rms (35 V/m peak) 80 – 1000 MHz
Electrostatic Discharge	8	-	±8 kV contact discharge ±15 kV air discharge
Vibration	9	-	Class V.S.2 10 mm/s, 1-150 Hz
Device cooling	10	-	convection cooled without fans


(Wolfgang Schenk
Managing Director)


(i.V. Peter Schumacher
Director Quality Management)

Neckartenzlingen, 2017-06-30
(Issue place and date)